

REPORT RD5 IN PROGRESS WORKS INTERRUPTION REPORT

File reference of the Technical Controller: 233338

Agency: CPV ARABIA

Engineers in charge of Inspection: Inspection Engineer4

Date of Issuing Report: 15-Sep-2024

OWNER: شركة يمامي القابضة

Accurate Address: حي عرفة

1 – ADMINISTRATIVE INFORMATION

1.1 Issue date and number of previous RD5 : NA

1.2 Work's Progress in Percentage: G: 10% S: 10% WP: 10

2 - SUBJECT : MAJOR MODIFICATION OF RISK

- | | | | |
|-----|-------------------------------------|---------------------------------------------------------------|----------|
| 2.1 | <input checked="" type="checkbox"/> | Modification of the consistency and the nature of main works: | |
| 2.2 | <input type="checkbox"/> | Stopping of inspection Date: | Motive: |
| 2.3 | <input type="checkbox"/> | Stopping of site works Date: | Motive: |
| 2.4 | <input type="checkbox"/> | Issuing of reserves (to attach copy). | Mention: |
| 2.5 | <input type="checkbox"/> | Other element justifying an information to insurers. | Mention: |

3 – COMPLEMENTARY INFORMATION, DETAILED OPINIONS, AND CONCLUSION


During the ongoing project, we have identified that the contractor cast concrete before the TIS visit, which poses a potential risk to the projects quality.

To address this issue, we will need to conduct on-site testing to confirm that the works have been executed based on SBC and engineering principles.



//

General picture of the project



Engineer In Charge of Inspection	Inspection Manager
Name: Inspection Engineer4	Name: Khaled Adel
